

HC-5 (Rev. 5/93)

CONTRACT CHANGE ORDER NO. 174 SUPPL. NO. 1
 ROAD 04-SF-80-13.2, 13.9 SHEET 2 OF SHEETS
 FEDERAL NO.(S) CONTRACT NO.: 04-0120F4

Add to the end of Special Provisions Section 10-4.05 "ELEVATOR," subsection "DECISION AND ORDER," bullet "A" the following:

4. The Contractor shall provide padding with 4-inch diagonal red and white striping at points of low overhead clearance in the control room to prevent head injury to maintenance personnel working in the area.
5. Durable signs with lettering not less than one-inch high on a contrasting background shall be permanently and conspicuously posted on the control room door and in the low overhead area; the signs shall read:
CAUTION
LOW OVERHEAD CLEARANCE
77.5 INCHES
6. Durable signs with lettering not less than one-inch high on a contrasting background shall be permanently and conspicuously posted along the entire length of the conductor bars. The signs shall be placed near the conductor bars at eye level at every landing and at intermediate intervals not exceeding every tower strut or cross-brace, wherever maintenance operations (including painting) could potentially be launched. The signs shall read.
DANGER
HIGH VOLTAGE
480 VOLTS AC

